



LEGEND

FLOOR STANDING FAN COIL UNIT

EXISTING FAN COIL UNIT

POLYPROPYLENE PIPE - FAN COIL SUPPLY

POLYPROPYLENE PIPE - FAN COIL RETURN

DISK VALVE

FLEXIBLE DUCT

FAN COIL CONTROLLER

C.D.	Ø100
560	3xø150

1. SLOT TYPE: CEILING DISCVLVE (C.D.)

1	2
3	4

2. SLOT DIMENSIONS (mm)

1	2
3	4

3. AIR FLOW (m³/h)

1	2
3	4

4. FLEXIBLE DUCT CONNECTION (mm)

FCU INDOOR UNITS TABLE						
A/A	TYPE OF UNIT	Qsc (kW)	Qtot (kW)	Qp (kW)	WATER FLOW (l/s)	OUTDOOR UNIT
FV200	FLOOR STANDING	1.0	1.2	3.1	190	—
FV300	FLOOR STANDING	1.7	2.3	5.9	400	—
FV400	FLOOR STANDING	2.4	3.3	8.5	555	—
FV600	FLOOR STANDING	3.5	4.8	12.4	820	—
FV800	FLOOR STANDING	4.2	5.6	14.5	950	—

CLIENT: **enisa**
European Network
and Information
Security Agency

PROJECT:
RENOVATION OFFICES

LOCATION:
**VASILISSIS SOFIAS 1, MAROUSI
ATHENS**

DRAWING:
**HVAC
SECOND FLOOR PLAN**

SCALE:
1:50

DRAWING NUMBER:
HV-04a

REVISION:
a: 05.02.14

DESIGN PHASE:
DETAILED DESIGN

PG KAMARINOS
CONSULTING ENGINEERS

8, KIFISSIAS AVE., ATHENS 115 26.
mail@kamarinos.com T. 210 6470910 F. 210 6470911

MANAGER:	A.P.K.	DATE:	23.12.13
ENGINEER:	C.H.S.	REFERENCE:	158ENI
DESIGNER:	E.P.M.	FILE NAME:	158HV04a.dwg